

SAFETY INSPECTION FOR MISCELLANEOUS EQUIPMENT
U.S. Army Engineer District, New Orleans

Date of Inspection:

Contractor or Unit	Contract No. or Activity
Inspected by (Signature)	Witness (Signature)

STRUCTURAL STEEL ERECTION

NOTE: Safety and Health Requirements Manual (EM385-1-1) references in parentheses.

	Yes	No	N/A
1 Are all required safety apparel and equipment furnished and use enforced? (Section 5)			
2 Is safe access provided to all work areas? (21.A.01) NOTE: Riding on hooks, buckets, material hoists, loads, etc. is prohibited. (16.C.14 and 16.K.11)			
3 Are stairways provided on all structures or work levels 20ft. or more in height? NOTE: Temporary stairways should be provided where permanent stairways are not installed concurrently with construction of each floor. (21.E.01)			
4 Are portable ladders secured top and bottom? (21.D.08 (d))			
5 Do the ladders extend at least 3ft. past the landing? (21.D.01 (b))			
6 Are floor or roof holes properly guarded with a securely anchored railing, intermediate rail and toe board? (24.A.01)			
7 Are safety nets being used where scaffolds, catch platforms, or temporary floors are impractical? (21.C.10)			
8 Are safety nets being inspected and debris removed daily as well as being tested regularly? (21.C.11 & 12 & 14)			
9 Are safety belts and life lines provided? (05.F)			
10 Are protective devices being used on roofing work which will protect workmen from slipping and falling and prevent workmen or the public on lower levels from being struck by falling objects? (27.H.01)			
11 Have all hoist towers been adequately inspected. (16.K.05)			
12 When electric powered hoist is used, has an automatic load-hold device been installed in case of power failure? (22.E.08)			
13 Are signal persons used when the operator cannot see the point of operations? (08.B.03)			
14 Is a standard signal system used? (16.C.10)			
15 Are tag lines or other means used to control loads? (14.A.06)			
16 Are the load rating plate and standard hand signal list attached to the hoisting equipment in view of the operator? (16.C.01)			
17 Have the hoisting equipment been inspected and tested? (16.A.01)			

REMARKS:
